

# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX26998  
**Report Reference** EX26998-20160428  
**Date** 2021-May-10

**Issued to:** T S I Metal Industries LLC  
P.O BOX 31165  
ABUDHABI AE

**This is to certify that  
representative samples of**

METALLIC SPRINKLER PIPE

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 852 UL Standard for Safety for Metallic Sprinkler Pipe  
for Fire Protection Service

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX26998  
**Report Reference** EX26998-20160428  
**Date** 2021-May-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL -

Schedule 10, 20, 30, and 40 steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems intended to be joined by threading, welding, or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

All pipes with threaded ends shall conform to ANSI B1.20.1.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, and 12 inch sizes as per ASTM A53, Grade A and B, Black or Galvanized, Type E.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, and 10 inch sizes as per ASTM A53, Grade A and B, Black or Galvanized, Type S.

Schedule 30 steel pipe in the 8 inch size as per ASTM A53, Grade A and B, Black or Galvanized, Type E.

Schedule 20 steel pipe in the 8 inch size as per ASTM A53, Grade A and B, Black or Galvanized, Type E.

Schedule 10 steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8 inch sizes as per ASTM A795 and ASTM A53, Grade A and B, Black or Galvanized, Type E.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

